



Filing Receipt

Received - 2022-01-11 10:01:19 AM
Control Number - 52667
ItemNumber - 23



Bluebonnet Electric Cooperative, Inc.

Project No. 52667 Compliance Report

This report was prepared by Bluebonnet Electric Cooperative, Inc. (BEC) to comply with PUCT Project No. 52667 regarding the Filing of Attestations Demonstrating Compliance with HB 4150.

Report Date	January 5, 2022
Entity	Bluebonnet Electric Cooperative, Inc.
Entity Type	Transmission and Distribution Service Provider
Lake listed in PURA § 38.004(b) in Bluebonnet EC Service Area	Lake Bastrop and Somerville Lake
County of Lake(s) and Distribution Line(s)	Bastrop, Burleson, Lee, Washington



Line and Compliance Information

Line Identifier	Compliance with NESC 232	Compliance Confirmation Date	Notes
BA110 Lake Bastrop	Yes	June 03, 2021	Existing Structures/Spans were surveyed and verified to be in compliance with NESC 232. Schneider Engineering reported no clearance issues.
PG50 Lake Bastrop	Yes	June 03, 2021	Existing Structures/Spans were surveyed and verified to be in compliance with NESC 232. Schneider Engineering reported no clearance issues.
SW20 Lake Bastrop	Yes	December 03, 2021	Existing Structures/Spans not in compliance with NESC 232 were identified on June 03, 2021. Structures/Spans were brought into compliance with NESC 232 and verified on December 03, 2021.
LN20 Somerville Lake	Yes	November 23, 2021	Existing Structures/Spans not in compliance with NESC 232 were identified on July 14, 2021. Structures/Spans were brought into compliance with NESC 232 and verified on November 23, 2021.
ZK40 Somerville Lake	Yes	November 23, 2021	Existing Structures/Spans not in compliance with NESC 232 were identified on July 14, 2021. Structures/Spans were brought into compliance with NESC 232 and verified on November 23, 2021.
ZK80 Somerville Lake	Yes	November 23, 2021	Existing Structures/Spans not in compliance with NESC 232 were identified on July 14, 2021. Structures/Spans were brought into compliance with NESC 232 and verified on November 23, 2021.
GH130 Somerville Lake	Yes	November 23, 2021	Existing Structures/Spans not in compliance with NESC 232 were identified on July 14, 2021. Structures/Spans were brought into compliance with NESC 232 and verified on November 23, 2021.

PROJECT NO. 52667

FILING OF ATTESTATION DEMONSTRATING COMPLIANCE WITH HB 4150

AFFIDAVIT OF COOPERATIVE OFFICER FOR

BLUEBONNET ELECTRIC COOPERATIVE, INC.

FILED PURSUANT TO SECTION 6 HOUSE BILL 4150

STATE OF TEXAS §

COUNTY OF BASTROP § BURLESON § LEE § WASHINGTON

BEFORE ME, the undersigned authority, on this day personally appeared, and who, after being duly sworn, stated on his or her oath he or she is entitled to make this Affidavit, and that the statements contained below are true and correct.

I, Eric Kocian, swear or affirm that as an Electric Cooperative operating in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system, confirms the following:

- Bluebonnet Electric Cooperative, Inc. (BEC) operates a distribution utility system in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system;
- BEC owns 7 feeders over lakes listed in PURA § 38.004(b).
- The report prepared by BEC, titled **Project No. 52667 Compliance Report**, certifies that these distribution lines meet the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).

Eric Kocian

{Signature of Officer of the Cooperative}

Chief Engineer and System Operations Officer
Bluebonnet Electric Cooperative, Inc.

Sworn and subscribed before me on this 6 day of January, 2022.

Tina Medack

Notary Public in and for the State of Texas

Notary Seal

(Must be notarized by a notary public in and for the State of Texas.)

